



Quick Summary Report
Seymour School District
Date: September 14, 2026
SES's Findings and Recommendations:

Accident Reduction (OSHA 300)

Lavesa Glover-Verhagen was reminded to have the form submitted to the agency division by March 1st and must be posted for all employees from February 1st to April 30th and was also reminded that the WI Department of Public Safety and Professional Services Accident Summary Form or The OSHA 300A Form must be submitted to the agency Division by March 1st.

Emergency Action Plan

Yes, the EAP is posted in every room of the District

There are AED's within the District

Monthly inspections of the fire extinguishers, emergency lighting, and exit signs are required and must be documented. **This shall be conducted by the District.**

There is a safety committee in the district

Greg Dobbs is the designated safety person

IEQ

Greg Dobbs is the designated person for all indoor environmental quality needs

Public notification was sent out either via mail/email/District website/ District newsletter

Blood Borne Pathogens

SES online provides the annual BBP training

The District currently does have a plan/procedure in place

The District does have BBP kits throughout the school

Asbestos O&M

Greg Dobbs is the Designated Person (DP)

There is no one certified to perform O&M operations



Asbestos Notification

The District provides the annually required asbestos notification to all District parents and staff either via mail/email/District website/District newsletter

Asbestos 6 Month Periodical

3-year was done in 2026

6-month surveillance was last done in September 2025

Asbestos Periodic Surveillance (40 CFR Part 763)

High School

12X12 floor tile and mastic

12X12 ceiling tile and mastic

Terrazzo floor

TSI Fittings

Stair treads

12X12 pinhole ceiling tile

Ceiling tile with flower pattern

HVAC vibration cloth

Water tank insulation

Rockledge Intermediate School

9X9 floor tile and mastic

Black Creek School

Fire Door

All accessible asbestos containing materials appeared to be in good condition.

Lead in Water

No record of when testing was done by the District

A proposal was sent to the District in October 2025, no testing has occurred.

The municipality does annual testing, although this occurs it is recommended to be tested every 5 years as the quality of the water can change upon entering the school building

Lead in Paint

There is no record that the paint has ever been tested for this District.

The Rockledge Primary was built in 1963

The Rockledge Intermediate was built in 1968



The Middle School was built in 1967
The High School was built in 1973
Black Creek was built in 1957

Only needs testing if there will be any major renovations if the school is older than 1978

Radon Gas

Within the District, radon testing occurred: 1990 there were no elevated levels at that time.

Not mandatory but recommended to be tested every 5 years

Pest Management

The District has contracted with Lakeland Lawn Care to assess and manage its herbicide needs.

The District has contracted with Terminix to assess and manage its pest problems as they arise (mice in the kitchen, ants in or around the building, etc.).

The District has no personnel who are certified and licensed to apply herbicides and pesticides. Therefore, no herbicides or pesticides should be applied at this time.

Infectious Disease

The School District has met the specification for the Emergency Plan for Infectious Diseases.

SES has reviewed/revised the written compliance plans for the District